

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20180411
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Hydrostatic Test	John DiMauro	Passed	Tuesday, December 18, 2018

Informational:

1 Misc

The Redford crew performed the hydrostatic pressure test on the 12" line segment from station 0+00 to the connection at 4+86.16

The line held at 150 psi for 2 hours.
Test passed.

Comments: