

# Inspection Summary

Permit #: PRPWFC20173802, Public Works Infrastructure Permit - Commercial  
Residences at Echelon  
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Coliform Test 1	John DiMauro	Passed	Tuesday, December 18, 2018

Informational

1 John DiMauro 12/18/2018 1:04 PM

This round of day 1 & day 2 samples for water line B were collected and delivered to Keystone Lab on 12/12/2018 & 12/13/2018.

Both day1 and day 2 samples passed the bacteria testing.

Water line B was put in service.

DEI-Water Line - Coliform Test 2	John DiMauro	Passed	Tuesday, December 18, 2018
-------------------------------------	--------------	--------	----------------------------------

Informational

1 We collected the day 2 samples for the water line B along Hollywood Dr. We will know the results friday afternoon 12/14/2018

Comments: