## CITY COMMENT RESPONSE 12-13-18

- I. WATER SUPPLY INSIDE OF BUILDING TO BE PEX
- 2. DWV TO BE PVC PIPE
- 3. GAS LINE TO BE CSST/IRON PIPE
- 4. EXTERIOR DOORS WILL HAVE COMBO PACK TO ILLUMINATE INTERIOR AND EXTERIOR OF DOORWAY





