

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20183262  
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Wednesday, December 19, 2018

Partial Correction:

1 Misc

OK TO COVER WHEN READY UNDER-SLAB CODUIT: **FROM DATA/ELECTRICAL ROOM LOCATION WEST UNDER FOOTING AND TO 80' S/SE TOWARD CLUBHOUSE;**

**Comments:**