

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20182457  
Address: 2602 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:   | Outcome: | Date:                       |
|---|--------------|----------|-----------------------------|
| <b>All Rough Inspection - Residential</b> | Mark Harding | Failed   | Thursday, December 20, 2018 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | -Provide plans on site at time of inspection.<br><br>plans show beam post in garage.<br>-install required erosion control at street. erosion control is down in the front.<br><br>-install stud or header over cut stud for hood. Exterior wall.<br>install full length stud in bearing wall from floor to top plate next to the hood.<br>or install header across the top of the hoos with jack stud.<br><br>*block hole in bottom plate north Side of 1st floor, missed cut for havc. stud bay south of the refrigerator still opne to floor space. |
|---|------|---|

**Comments:**