

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20180700
Address: 217 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Mark Harding	Failed	Thursday, December 20, 2018

Corrective Action Required:

1	Misc	PARTIAL- MAIN TRUCK LINE ONLY
		UPPER LEVEL-
		NORTH END INCOMPLTE NEED TO BED PIPE IN GRAVEL

Comments: