

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20182837  
Address: 450 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DEI-Curb - Proof Roll</b>	Ronald Paynter	Passed	Monday, December 24, 2018

Informational:  
1 Misc Larry Bair had a tandem dump truck with a full load of aggregate. Sub base was solid, no pumping or rutting was detected.

**Comments:**