

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182521
Address: 4708 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, December 26, 2018

Corrective Action Required:

1	Misc	-Seal penetrations of ceiling return air space above master closet
		-Addendum: at the master closet/garage wall return air, add direct stud support for joists
		-Install hangers for double beam connections to triple beam above 2nd fl bath. The wall is not a bearing wall.
		-Align I beam support columns per plan near stair. Move the steel column near the stair to middle of the pad

****OK TO INSULATE**

Comments: