

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20180333
Address: 1607 SW BLACKSTONE PL, LEES SUMMIT, MO 64082
Inspected On: Friday, December 28, 2018
Inspected By: Mark Harding
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Temporary C of O	Friday, December 28, 2018

Corrective Action Required:

1 Misc

- INSTALL LAG BOLT PER MANUFACTURE, PROVIDE LISTING ON BOLTS USED. NEED TO BE CLOSER THAN 16"O.C.
- NO DECK TO POST ATTACHMENT. CONNECT DECK POST TO DECK PER CODE FOR UPLIFT.
- LAWN SPRINKLER PERMIT
- SOD EROSION CONTROL, CLEAN STREET, WATER METER FLUSH WITH GRADE.