

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20182146  
Address: 1700 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Jason McRoy	Failed	Wednesday, January 02, 2019

Corrective Action Required:

1	Misc	No physical address Spark rings required at kitchen outlets located in back splash No handle or lock on sliding glass door No secondary locking device on sliding glass door No smoke alarm on 2nd fl outside of bedrooms Dryer vent is not terminated to outside Sod Splash blocks
---	------	--

Comments: