



FOR OFFICE USE ONLY			
Inspector:	CDV	Sub/Builder:	Dave Richards Home Bldg
Time On:	11:15 AM	Time Off:	11:30 AM Temp: 81°

June 6, 2018

Gary's Foundation

Re: 4712 NE Pocono Circle
Lot 36, Monticello
Lee's Summit Permit #: 2018-1463

Apex Engineers, Inc. observed the footing forms and reinforcing steel for the foundation located at the above referenced address.

The footing forms and reinforcing steel were found to be clean, well aligned, properly supported and in compliance with the on-site approved foundation print. At the time of inspection, erosion control had been installed.

Notes:

- The UFER ground was installed at the time of our firm's inspection.
- The garage pier pads were not placed at the time of our firm's inspection.

Our firm recommends approval of the footing forms for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction.

Limitations: The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. These conditions may be altered over time and/or with changes in the weather. If changes in the condition of the site occur, Apex Engineers, Inc. shall be called for a re-inspection. The scope of our services does not include an evaluation of job site hazardous conditions, OSHA compliance, or an environmental assessment. Furthermore, the contractor shall retain sole responsibility for the quality of work, for adhering to plans, specifications, appropriate codes, and for repairing defects, deficiencies or omission, regardless of when they are found. By use of this report, all applicable parties agree to the terms and conditions of Apex's Master Service Agreement.

This report is to certify that I, or qualified individuals working under my direction, observed the above checked items in accordance with the applicable approved building and site plans, previous inspection results, codes and engineering details. The work is completed and to the best of my knowledge was found to be in general compliance with the City approved plans and specifications.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,

Apex Engineers, Inc.
Missouri License Number: 2003004673
Clayton J. Hess, P.E.
Principal

