



PLAN REVIEW CONDITIONS

January 09, 2019

GUY GRONBERG ARCHITECTS
113 SE 3RD ST
LEES SUMMIT, MO 64063

Permit No: PRCOM20190033
Project Title: SKRATCH BAKERY
Project Address: 862 SW BLUE PKWY, LEES SUMMIT, MO 64063
Parcel Number: 61420023800000000
Location: SEC 7 TWP 47 RNG 31 PT OF N 1/2 NW 1/4 DAF: BEG ON W LI NICHOLS ST AT A PT 250' S OF S
LI 3RD ST TH TH S 10' TH E 405' MOL TO POB
Type of Work: CHANGE OF TENANT
Occupancy Group: MERCANTILE
Description: TENANT FINISH FOR NEW BAKERY

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Joe Dir

Rejected

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Action Required:(Verified at inspection)

Address Front and Back Doors. Address shall be readable from roadway.

2. 2012 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10. Action required:(Verified at inspection)

Provide a minimum of one 2A10BC Fire Extinguisher. Fire Extinguisher will be mounted on a wall near an exit.

3. IFC 2012 1008.1.9 Door operations except as specifically permitted by this section egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.
Action Required: No keyed locks on the interior side of an egress.

4. Egress Illumination:
(Action Required)

Rear door is marked as an exit. Add exterior remote head at exit discharge.

[B] 1006.1 Illumination required. The means of egress, including the exit discharge, shall be illuminated at all times the building space served by the means of egress is occupied.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.