

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20183479  
Address: 1450 SE BROADWAY DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Mike Copeland	Partial	Wednesday, January 09, 2019

Partial Correction:  
1 Misc COLUMNS PADS ON PLANS HAVE CONFLICTING DETAILS.  
INSTALLED 2 MATS #4 BARS EACH WAY. HAVE ENGINEER ADDRESS. POUR AT OWN RISK.

**Comments:**