

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20182626  
Address: 833 NW DONOVAN RD, Unit:G2, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Passed	Wednesday, January 09, 2019

**Comments: OK TO POUR WHEN READY PERIMETER TRENCH FOOTING. ENSURE MINIMUM 3" CLEARANCE FROM RE-BAR TO BOTTOMS & BANKS.**