

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20182837  
Address: 450 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DEI-Commercial Curb Inspection</b>	Dan Harper	Partial	Wednesday, January 09, 2019

Informational:

1 Misc

Talked with John from the contracting company on site.

AB-3 base around the curb radius had adequately placed thickness and compaction for curb placement. I informed contractor that cure and cover was required for concrete due to the nighttime temperatures.

**Comments:**