

David P. Ainsworth, P.E.  
P.O. Box 597, Buckner, MO 64016  
Cell Phone: 816-682-2093  
Email: [dainsworth@chelepis.com](mailto:dainsworth@chelepis.com)

January 10, 2019

Dave Richards  
Dave Richards Homebuilding, Inc.  
P.O. Box 1325  
Blue Springs, MO 64013

Re: 4712 NE Pocono Cir  
Lot 36 Monticello  
Lee's Summit, MO  
Permit # PRRES20181463

Dear Mr. Richards:

On January 10, 2019, I inspected the above referenced property to address attachment of triple 2x10 support beams to 6x6 posts supporting the floor framing for the Sun Room. I recommend making that attachment with 5" x 5" x 1" wide galvanized steel angles. The 5" legs of each angle should be attached to the post and to the triple 2x10 beam with 3 @ 2-1/2" x 3/8" Timber Lag fasteners.

If you have questions feel free to contact me at your convenience.

Cordially,



David P. Ainsworth, P.E.

