

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182860
Address: 697 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Monday, January 14, 2019

Corrective Action Required:	
1 Misc	CONFIGURATION HAS BEEN MODIFIED. SUBMIT REVISION TO LS PLAN REVIEW.
Corrective Action Required:	
2 Misc	CHECK & REPAIR CUT UNDER-SLAB ELECTRICAL CONDUIT (AND CABLE?).
Corrective Action Required:	
3 Misc	EXPOSE SANITARY CONNECTION TO BUILDING DRAIN

Comments: