

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182892
Address: 4419 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Monday, January 14, 2019

Corrective Action Required:

1	Misc	-FIRESTOP AROUND 3" DWV FIRST FLOOR MECH. CHASE -TRUSS HANGER CORNER TRUSS OVER STAIRS -NAIL COVERED PORCH GIRDER TRUSS -FLASH ALL PLUMBING VENTS -2ND FLOOR MECHANICAL CHASE, FIREBLOCK TO ATTIC
---	------	---

Comments: