

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20180348
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Hydrostatic Test	John DiMauro	Passed	Tuesday, January 15, 2019

Informational:

1 Misc

The Redford Construction crew performed the Hydro test on water lines # 4 & 5. Both lines are connected to Water line # 1 for The Reserve at Stoney Creek 3rd plat and all lines for both subdivisions were tested simultaneously. I observed the crew pressure up the water line to 150 psi and stayed on site while the line held for two hours. The test passed.

Comments: