

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20182996
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Air Test	Joe Starlin	Partial	Tuesday, January 15, 2019

Corrective Action Required:

1	Misc	1/15/19 Air test has been completed and passed from existing manhole on the south side of Victoria to manhole A-1. Air test from A-1 to A-2 is complete and passed. Air test from A-2 to A-3 is complete and passed. Air test A-3 to A-4 is complete and passed. We intend to test A-4 to A-5 on 1/16/19.
---	------	---

Comments: