

Inspection Summary

Permit #: PRSUBD20182996, Development - Subdivision

Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection	Joe Starlin	Partial	Friday, January 11, 2019

Informational

1 All erosion control measures are in place properly.

DEI-Sanitary - Material Verification	Joe Starlin	Passed	Friday, January 11, 2019
--------------------------------------	-------------	--------	--------------------------

Informational

1 All material on site for sanitary construction have been verified and meet the standard specifications.

DEI-Detention Basin	Joe Starlin	Partial	Friday, January 11, 2019
---------------------	-------------	---------	--------------------------

Informational

1 The 13,673 cu. ft. underground detention system has been installed and covered. The inspector for Contech Engineered Solutions John Willhoite was on site daily for the installation. He will be sending a report on the detention system.

DEI-Storm - Material Verification	Joe Starlin	Partial	Friday, January 11, 2019
-----------------------------------	-------------	---------	--------------------------

Informational

1 All storm material on site appears to meet specifications.

DEI-Storm - Sewer
Construction Inspection

Joe Starlin

Partial

Friday,
January 11,
2019

Informational

1 Storm inlet 601,602, and 501 have been installed along with storm pipe.

Comments:
