

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20182092  
Address: 1611 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Jason McRoy	Failed	Thursday, January 17, 2019

Partial Correction:

1	Misc	-plumbing protection plate east wall front bedroom .  -install floor box at rear great room. -install floor outlets along stair opening per code. -firestop dbl wall at stair/ garage wall.  - firestop over bsmt window NE bedroom from josit space. -plumbing protection plates NE bsmt bedroom at bath wall.  -firestop all tub shower traps. - holes drilled in bottom 2" josit over bar sink and NW bsmt bath.
---	------	---

**Comments:**