

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20183043  
Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	John Borns	Partial	Thursday, January 17, 2019

Partial Correction:

1	Misc	HOOD SECTION LIGHT TESTED ON THE GROUND AND APPROVED; JOINT WELD AT TOP OF HOOD LIGHT-TESTED OK; <b>1ST LAYER DUCT WRAP OK TO COVER;</b>
---	------	--

**Comments:**