CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20171839

Address: 4012 SW MERITAGE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Jason McRoy Failed Friday, January 18,

Residential 2019

Corrective Action Required:

1 Misc * INSTALL SPARK RINGS AT KITCHEN OUTLETS LOCATED WITHIN BACKSPLASH.

Comments: