

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182137
Address: 4012 SW MERITAGE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Failed	Friday, January 18, 2019

Corrective Action Required:

1	Misc	*PLUMBING INCOMPLETE AT BAR SINK. *FIREBLOCKING REQUIRED THROUGHOUT, AT TOP PLATE TO JOIST SPACE ON OUTSIDE WALLS, OUTSIDE WALL NEED TO BE FIRE BLOCKED VERTICALLY AT 10' INTERVAL. *BASEMENT BED NEEDS TO BE ON ARCH FAULT BREAKER
---	------	---

Comments: