

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20180838
Address: 1841 SW BLACKSTONE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Friday, January 18, 2019

Corrective Action Required:

1	Misc	Install security screws at rear entry. Protect wiring that runs parallel to hvac duct work in basement. Water main is leaking at main shut of valve in basement. Cannot test Nest smokes. Install lockouts on micro/ stove breakers. Ceiling at covered deck to be caulked and painted. Final grading. Sod.
---	------	--

Comments: