

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181827
Address: 2420 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Tuesday, January 22, 2019

Corrective Action Required:

1	Misc	- final grade , sod , erosion control, splashblocks, water meter. -deck supported by cantilever. - DBL header left south side spliced in middle. -hanging light fixture over master bathtub. -open globe fixture over basement tub/shower.
---	------	--

Comments: