

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182615
Address: 837 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Concrete Walls and Columns Inspection	John Borns	Passed	Tuesday, January 22, 2019

Comments: PERIMETER STEM WALLS OK TO POUR WHEN READY.