

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170405
Address: 3550 SW HOLLYWOOD DR, Unit:5, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mike Copeland	Partial	Wednesday, January 23, 2019

Partial Correction:

1	Misc	-3rd FLOOR ABOVE CEILING, ALL APPROVED EXCEPT DAMPERS IN ASSEMBLY AT CHANGE OF ELEVATIONS. -2ND FLOOR CEILING APPROVED
---	------	---

Comments: