

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170405

Address: 3550 SW HOLLYWOOD DR, Unit:5, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mike Copeland	Failed	Wednesday, January 23, 2019

Corrective Action Required:

1	Misc	-INSTALL PUTTY PADS ON BOXES LOCATE WITHIN 24" OF EACH OTHER IN THE SAME SPACE.
---	------	---

Comments: