

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20180838  
Address: 1841 SW BLACKSTONE CT, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mike Copeland	Failed	Friday, January 25, 2019

Corrective Action Required:

1 Misc

Cannot test test smokes. Smoke alarm function cannot rely on internet/network function. Required to be hard wired/interconnected with a battery back up.

Final grading.  
Sod.

**Comments:**