

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20180252  
Address: 1600 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DEI-Sanitary Sewer Construction Inspection</b>	John DiMauro	Partial	Monday, January 28, 2019

Informational:

1	PW-Main inspection	The crew is on site continuing the sanitary service line.
---	--------------------	---

Informational:

2	PW-Main inspection	John DiMauro 04/20/2018 3:38 PM
---	--------------------	---------------------------------

The crew installed approximately 250' ft of the sanitary service line. The fittings are the correct type and there appears to be sufficient rock surrounding the pipe.

Informational:

3	Misc	The American Dirt Works crew is on site installing the new revised sanitary sewer line on the private side. The crew bored under the parking lot for the 4" service line.
---	------	---

**Comments:**