

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182137
Address: 4012 SW MERITAGE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Failed	Tuesday, January 29, 2019

Partial Correction:
1 Misc

*FIREBLOCKING REQUIRED AT SOUTH WALL FIR DOWN SPACE TO STUD SPACE
FROM EAST END OF FIR DOWN TO WEST END OF FIR DOWN
*BASEMENT BED NEEDS TO BE ON ARCH FAULT BREAKER

Comments: