

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20180252  
Address: 1600 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DEI-Sanitary Sewer Construction Inspection</b>	John DiMauro	Partial	Friday, November 30, 2018

Informational:

1	PW-Main inspection	The crew is on site continuing the sanitary service line.
---	-----------------------	---

Informational:

2	PW-Main inspection	John DiMauro 04/20/2018 3:38 PM
---	-----------------------	---------------------------------

The crew installed approximately 250' ft of the sanitary service line. The fittings are the correct type and there appears to be sufficient rock surrounding the pipe.

**Comments:**