

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170403
Address: 3540 SW HOLLYWOOD DR, Unit:4, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mike Copeland	Failed	Tuesday, January 29, 2019

Corrective Action Required:

1	Misc	3RD FLOOR ONLY, COMPLETE BATH FAN INSATLLATION. NAIL HEADERS. SEAL PENETRATIONS IN DRAFTSTOP SYSTEMS. STRAP BEARING TOP PLATES DRILLED OVER 50%
---	------	---

Comments: