CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170405

Address: 3550 SW HOLLYWOOD DR, Unit:5, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Electrical Service Inspection - Mike Copeland Failed Friday, February 01,

Commercial 2019

Corrective Action Required:

1 Misc First floor units only: SEAL PENETRATIONS IN DRAFT STOPS FOR FLOOR

JOISTS. INSTALL CLEANOUTS AT THE BASE OF ALL PLUMBING STACKS.
PROTECT ALL PLUMBING AT THE BASE 3" FROM THE FLOOR. NORTH UNIT,

FIREBLOCK NORTH WALL DEAD SPACE. DO NOT COVER

Comments: