

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170403

Address: 3540 SW HOLLYWOOD DR, Unit:4, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|---------------|----------|---------------------------|
| Above Ceiling Inspection | Mike Copeland | Partial | Friday, February 01, 2019 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | 3rd floor: need to see bath fan dampers through rated assembly. Okay to begin rated lid |
|---|------|--|

Comments: