

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183043
Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|---------------------------|
| Gas Piping Inspection - Commercial | John Borns | Failed | Friday, February 01, 2019 |

Corrective Action Required:
2 Misc PAINT GAS PIPE 100% PER IFGC.
COMPLETE INSTALLATION OF PIPE CLAMPS AT SUPPORT BLOCKS.

Comments: