

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183161
Address: 3324 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Jason McRoy	Failed	Monday, February 04, 2019

Corrective Action Required:

1	Misc	restore laterral at 3328 sw jessie ln. Locate stub for 3324 sw jessie ln and make proper connection. Work to be completed by A-Brite plumbing within the next 2 days.
---	------	---

Comments: CALL IN SEWER INSPECTION, WHEN STUB AND ALL REPAIRS ARE VISIBLE