

**DEVELOPMENT SERVICES**

**PLAN REVIEW CONDITIONS**

February 08, 2019

AXXYS CONSTRUCTION GROUP  
4101 NICOLS ROAD STE 100  
EAGAN, MN 55122

Permit No: PRCOM20184084  
Project Title: FOREVER 21  
Project Address: 840 NW BLUE PKWY, Unit:M, LEES SUMMIT, MO 64086  
Parcel Number: 51700033700000000  
Location: SUMMIT FAIR, LOTS 31 & 32-PT LOT 32 DAF: BEG NW COR SE 1/4 SEC-36 TWP-48 RNG-32 TH S 2 DEG 28 MIN 52 SEC E & RAD 139') 74.01' TH S 00 DEG 57 MIN 28 SEC W 65.80' TH S 89 DEG 10 MIN 24 SEC E 231.21' TH S TH SELY ALG LF CURV (RAD 111') 67.86' TO POINT OF REVERSE CURV SELY & SLY ALG RI CURV (RAD 139') 85. W 44.01' TH S 79 DEG 07 MIN 37 SEC E 49.50' TH S 10 DEG 52 MIN 23 SEC W 54.98' TH S 2 DEG 59 MIN 20  
Type of Work: CHANGE OF TENANT  
Occupancy Group: MERCANTILE  
Description: TENANT FINISH FOR RETAIL SALES OF CLOTHING AND ACCESSORIES

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

**Fire Plan Review**

**Reviewed By: Joe Dir**

**Approved with Conditions**

1. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

ACTION REQUIRED:(informational purposes)

Have the fire alarm system contractor provide 3 sets of PE stamped shop drawings of the modifications to be done to the fire alarm system

2. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:(verified at inspection)

The exterior of all doors leading into the suite shall be addressed with the suite designation address.  
Address shall match the other suites addressing and be readable from the roadway.

3. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

ACTION REQUIRED:(information purposes)

Have the Fire sprinkler system contractor provide 3 sets of PE stamped shop drawings of the modifications to be done to the fire sprinkler system.

4. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Acceptance testing of any modifications done to the fire alarm system is required. Testing shall be completed prior to the final occupancy inspection. Contact the fire department to schedule testing.

(816)969-1300

7. electrical Demolition

ACTION REQUIRED:(Informational Purposes)

The fire alarm system contractor shall be contacted prior to any disconnection, relocation, or demolition of any existing fire alarm systems devices.

#### **Building Plan Review**

**Reviewed By: Joe Frogge**

**Approved with Conditions**

2. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

1/8/19 - acknowledged in letter

#### **Licensed Contractors**

**Reviewed By: Joe Frogge**

**Approved**

- ☒ Approved to issue per the listed conditions.  
☐ Do not issue per the listed conditions.  
☐ Approved to construct foundation only per the listed conditions.  
☐ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

\_\_\_\_\_  
Signature of Applicant

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Applicant Name

\_\_\_\_\_  
CompanyName

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***