

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181393
Address: 1829 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Monday, February 11, 2019

Corrective Action Required:

1	Misc	Install shower enclosure at master bath. Install shower enclosure at guest bath main floor. Install ledger locks or equivalent lag bolts at deck ledger board. Open electric box in master bath. Lockouts on oven and micro breakers Final grading Sod. splash blocks provide as graded plot plan prior to sodding
---	------	--

Comments: