## **Inspection Summary**

Permit #: PRSUBD20180411, Development - Subdivision

The Reserve at Stoney Creek 3rd Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item: Inspection:		Inspector:	Outcome:	Date:
DEI-Wate 2	er Line - Coliform Test	: John DiMauro	Passed	Monday, February 11, 2019
Informational				
1 Informati	We collected the day 2 samples for the entire water line including the Manor at Stoney creek. We delivered the samples to Keystone Labs. We will know the results in 24 hours. tional			
2	John DiMauro 02/11/2019 3:15 PM			
	The day 1 & 2 samples passed the bacteria tests.			
	Today we put the lin	es in service.		
DEI-Wate 1	er Line - Coliform Test	: John DiMauro	Passed	Monday, February 11, 2019
Informational				
1	The Redford Construction crew pulled water samples for the entire water line including the two dead end lines for the Manor at Stoney Creek. I was on site during work and collected and delivered the samples to Keystone Labs for testing. We will know the results of the tests in 24 hours.			

## Comments:

220 SE Green Street | Lee's Summit, MO 64063 | 816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development