

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181582
Address: 2544 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Tuesday, February 12, 2019

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Provide revised plans showing walk out basement walls and framing.-provide attic access for 2-3rd car attic.-north garage header strap needs to extend to top plate.-fur out heat duct garage wall.-support DWV 1st floor and basement.-support flex ducts in attic 6' o.c.
---	------	--

Comments: