

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170403

Address: 3540 SW HOLLYWOOD DR, Unit:4, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mike Copeland	Failed	Thursday, February 14, 2019

Partial Correction:

1	Misc	2nd and 3rd floor approved to cover
---	------	-------------------------------------

Corrective Action Required:

2	FIRST FLOOR	-UNIT NORTH OF NORTH STAIRS, FIREBLOCK AND FIRESTOP DEAD SPACES -FIRESTOP FEEDERS FAR NORTH GARAGE WALL -COMPLETE WIRING NORTH COMMON AREA
---	-------------	--

Comments: