

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181760
Address: 2416 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Thursday, February 14, 2019

Corrective Action Required:

1	Misc	- exterior sod, erosion, splashblocks etc. -mstr AFCI does not trip. -install correct Floor outlet cover plates. -Seal garage door opener penetrations.
---	------	--

Comments: