

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20183043  
Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Failed	Friday, February 15, 2019

Corrective Action Required:

1	Misc	COMPLETE HVAC DUCTWORK
---	------	------------------------

Corrective Action Required:

2	Misc	IPC 305 PROTECTION OF COPPER PIPING AT POTENTIAL CONTACT WITH STEEL OR OTHER DISSIMILAR METALS: ELIMINATE CONTACT; THEN INSTALL GROMMETS OR OTHER APPROVED PROTECTION FROM SHARP EDGES & DISSIMILAR METAL.
---	------	--

Corrective Action Required:

3	Misc	IPC 905.2; IRC P3104.2 GRADING OF VENT PIPING TO DRAIN. MAY NOT BE RUN LEVEL.
---	------	---

**Comments:**