

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181582
Address: 2544 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Wednesday, February 20, 2019

Corrective Action Required:

1 Misc

-provide attic access for 2-3rd car attic.
ACCESS INSTALLED WITHIN 6 FEET OF NM CONDUCTORS. CONDUCTORS NEED TO BE INSTALLED ON RUNNING BOARDS TO PREVENT PHYSICAL DAMAGE.

OKAY TO INSULATE

Comments: