

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183043
Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Partial	Thursday, February 21, 2019

Corrective Action Required:

1	Misc	NEC 370-20; IRC E3806.5-6 SET-BACK OF ELECTRICAL RECEPTACLE / SWITCH BOXES: 1/4" MAXIMUM SET-BACK @ NON-COMBUSTIBLE SURFACES. CHECK ALL.
---	------	--

Corrective Action Required:

2	Misc	NEC 314.16; IRC E3905.13 ELECTRICAL BOX FILL: CHECK ALL ELECTRICAL BOXES FOR BOX FILL RESTRICTIONS -- CORRECT AS NEEDED
---	------	---

Corrective Action Required:

3	Misc	OK TO DEVICE RECEPTACLES AND SWITCHES AND INSTALL LIGHT FIXTURES AT SPACE 107 -- EXCEPT AT WEST WALLS WHERE SPARK RINGS ARE REQUIRED.
---	------	---

Comments: