

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183262
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-------------------------------|
| Underslab Plumbing Inspection - Commercial | John Borns | Partial | Tuesday, February 26, 2019 |

Partial Correction:

| | | |
|---|------|---|
| 1 | Misc | OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT: LEFT WING COMPLETE; BUILDING DRAIN FROM LEFT WING S/SE TO NEAR EAST ELEVATOR; BRANCH PIPING AT CENTER SECTION; BUILDING DRAIN EXTENDED SE/E TO (AAK); BUILDING DRAIN EXTENDED E TO 5' O/S E B/L; BRANCH PIPING TO COMPLETE DWV AT RIGHT WING |
|---|------|---|

ENSURE PRESSURE-TESTING OF PIPING SYSTEM IS PERFORMED PER IPC 312

Partial Correction:

| | | |
|---|------|---|
| 2 | Misc | OK TO COVER WHEN READY UNDER-SLAB RADON PIPING AT: LEFT WING; |
|---|------|---|

Comments: