

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20181886  
Address: 4733 NE GATEWAY DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, February 26, 2019

Corrective Action Required:

1	Misc	-Install hangers for lvl-lvl connections and joist-lvl connections at stair **Check later per engineer report  **Exposed TJI joists must be protected per IRC501. Check on final **OK TO ROCK
---	------	---

Comments: